



RESOLUTION 77, 2022

EMERGENCY RESOLUTION AUTHORIZING
REPAIR OF THE JUVENILE AND FAMILY SERVICES FACILITY
HVAC SYSTEM

THE BOARD OF CLALLAM COUNTY COMMISSIONERS finds as follows:

1. Clallam County Juvenile and Family Services Facility has been experiencing significant issues with the HVAC system – Trane Heat Pump Model CGWD0604CFOHTD104FFOUTU Serial U93K09165 from 1989.
2. On Monday, July 25, 2022 one of the four compressors on the chiller unit failed.
3. The HVAC system is a critical system not only for Juvenile and Family Services Facility staff but for the Juvenile Detention Center.
4. Parks, Fair and Facilities Department contacted Hermanson Company LLC to repair the unit. The contractor estimated \$25,000 to repair the HVAC system.

NOW, THEREFORE, BE IT RESOLVED by the Board of Clallam County Commissioners, in consideration of the above findings of fact:

1. Commissioners finds that there is a critical need to repair the HVAC System immediately within the Juvenile and Family Services Facility.

PASSED AND ADOPTED this 26th day of July 2022

ATTEST:

Handwritten signature of Loni Gores in blue ink.

Loni Gores, CMC, Clerk of the Board



BOARD OF CLALLAM COUNTY COMMISSIONERS

Handwritten signature of Mark Ozias in blue ink.

Mark Ozias, District 1Handwritten signature of Randy Johnson in blue ink.

Randy Johnson, District 2Handwritten signature of Bill Beach in blue ink.

Bill Beach, District 3